



WATERPRO BACKFLOW REQUIREMENTS

In order to comply with the Utah Public Drinking Rules, Section R309-105-12 Re: backflow, WaterPro has adopted the following policy. It is required that connections between a drinking water system and any other system (cross-connections) that may introduce pollutants or contaminants into the drinking water through backflow, be documented and protected by an approved backflow assembly. Aspirators, fire suppression systems, reverse osmosis systems, boilers and chemical injection systems (i.e. janitor closets, swimming pools) of any kind are examples of where backflow protection is required. If your property is equipped with *any* type of cross connection, it must be reported to WaterPro immediately.

Sprinkler systems that can utilize any culinary water have to have approved backflow protection in place on the system. It is required that all backflow assemblies be inspected and documented by your water company. If your landscape is in progress or recently completed, please call our office and request an inspection. It is not necessary that you be present during the inspection unless your backflow assembly is not accessible.

Contact our office with any questions or concerns about backflow and cross-connections.