



NOTE:

- NO REVERSE THRUST BLOCKS WITHOUT APPROVAL FROM THE WATER COMPANY.
- ALL DUCTILE IRON PIPE TO BE GREASED (FM) AND POLY WRAPPED.

TABLE OF DIMENSIONS		
NO.	OBSTRUCTION	
	SEWER MAIN	OTHER
(A)	18"	2"
(B)	10'-0"	6"
(C)	18"	12" MIN.
(D)	FULL PIPE LENGTH	O.D. + 12"

SCALE: N.T.S.

<b>DRAPER IRRIGATION</b> 12421 SOUTH 800 EAST DRAPER, UT 84020 (801) 571-2232	<h2 style="margin: 0;">WATERLINE LOOP DETAIL</h2>	DESIGNER X REVIEWED X SHEET	CAD JRK PROJECT NO 98-DI-001 1 OF 1	